



RAJKOT MUNICIPAL CORPORATION

સ્વચ્છ
સર્વેક્ષણ
ભાગ 2Q2Q



Fire And Emergency Services

Dr. Ambedkar Bhavan, Dhebar Road, Rajkot - 360 001. Phone No.0281 2227222.

RMC/RFES/B106/Renew School Building/NOC/610/2021.

Date.25.08.2021.

FSCA/O/CFORMC/2021/00008787.

:-: RENEW FIRE NO OBJECTION CERTIFICATE :-:

Ref. No.1.R.M.C.F.B.E.NO.NOC.627, DATE:-05.08.2021.

2.RMC/F.B./OLD NOC/No.133, Date :-23.06.2020.

This is to Renew Fire No Objection Certificate That with Reference 1 & 2 to Above Application of School Building Owner Rajkot Diocese Trust Christ School/Principal " **CHRIST SCHOOL - RAJKOT** ", Building Floor:-Cellar+G.F.+4th Floor, H.B.16.50 MT. Location:-Bishop's House, P.B.No.1501, Kalawad Road, Rajkot-360 005 (Guj.), India, Type of Building:-Frame Structure, Use of Building:-Education (Higher Secondary), Building No.A, R.Sr.No.104/1, 104/2, 105, 123/P, Village :-Nanamava, Ward No.10, T.P.S.5 (Nanamava), O.P.No.27, F.P.No.325. Building Site Was Inspected by RMC Fire Brigade Fire Station Officers and The Documents Submitted Were Checked and Found Correct on Date:-18.08.2021.

- During inspection of the said premises following system were found adequate and in working condition.

- (1) Fire Hydrant System with Hose Box, Hose Pipe with Nozzle & Hose Reel in Working Condition each floor.
- (2) ABC Fire Extinguishers 6 kg Capacity each floor.
- (3) CO2 Fire Extinguishers 4.5 kg Capacity each floor.
- (4) Fire Pump ON/OFF Switch each floor.
- (5) Emergency Fire Alarm System each floor.
- (6) Cellar + Ground Floor Area Fire Sprinkler System.
- (7) Two way fire Service inlet 2 way.

- You are hereby advised to maintain the above system in good working condition.

- (1) The Fire Fighting System to be Maintain perfect working condition all the time.
- (2) In Case of Emergency Fire Safety System must be operated by your trained person immediately.
- (3) The Fire Department of RMC will not be responsible for any loss of life & property Due to Fire/Emergency incident of your premises.
- (4) Electric Wiring must be proper and that Not be Loose and Taped in Building Area.
- (5) Fire Water Tank for fire fighting in Above area.
- (6) Trained man power shall be available for Fire fighting premises round the clock.
- (7) Our fire Certificate is limited to Fire Fighting System available in your premises Only.
- (8) Any other instructions given by fire Department from time to time about fire Safety of the premises to be followed.
- (9) This Certificate is Valid Up to One Year From The Date of Issue OR Till The Fire Protection System & Equipments Installed are Working Condition whichever is Earlier.

Dy. Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation



Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation

PLY-2021-2022 Fire NOC Date-01.04.2021 To Date-31.03.2022 (School & College & Gases F Fire 2021
2022/627 Christ School Rajkot Renew 2021.